

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1394:115

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Apollo Fire Detectors Ltd, 36 Brookside Road, Havant, Hampshire, P09 1JR, England
Contact: Gordon Ash +44(0)23 9249 2412 FAX +44(0)23 9249 2754

DESIGN: XP95A Model 55000-750 isolator and 45681-211 isolator base. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed compatible fire alarm control units. Model 55000-750 is only intended to be installed in the 4-wire redundant Style 7 of the Gamewell listed Models 620, 630, and 650 (CSFM Listing No. 7165-1288:144) fire alarm control units. Refer to listee's Installation Instruction Manual for details.

06-20-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**